

UL-EU CERTIFICATE

Certificate No.
UL-EU-01351-EN

Issue date
2025-12-18

Issue No.
1

Re-Issue date
-

Expiry date
2035-12-17



4705

This is to acknowledge that:
ROCKWOOL Ltd

Address:
ROCKWOOL Limited, Wern Tarw, Pencoed, Bridgend, CF35 6NY

Has had the product:
FirePro Flex Seal

evaluated and meets the requirements of the standard(s):

EAD 350454-00-1104, September 2017

Places of production:
ROCKWOOL Ltd, Unit 2, Hams Hall, Canton Lane. B45 1GA,
Birmingham

Authorised Signatory:

Chris Johnson
Issued by UL International (UK) Ltd

This is to certify that representative samples of the Certified Product listed above have been investigated by Underwriters Laboratories to the Standard(s) indicated on this Certificate, in accordance with the UL Global Services Agreement and the UL-EU Mark Service Terms and Conditions ("Agreement"). The Certificate Holder is entitled to use the UL-EU Mark for the Certified Product listed on the certificate and manufactured at the production site(s) listed, in accordance with the terms of the Agreement. Only those products bearing the UL-EU Mark for Europe should be considered as being covered by UL's UL-EU Mark Service. This Certificate shall remain valid through the Expiration date, unless a Standard identified on this Certificate is amended or withdrawn prior to that date or there is a non-compliance with the Agreement.



Appendix UL-EU CERTIFICATE UL-EU-01351-EN

This certificate relates to the use of FirePro Flex Seal for fire stopping of service penetrations through walls. The detailed scope is given in pages 3 to 17 of this Certificate. This shows the thickness and acceptable dimensions, substrates and orientations required to provide fire resistance periods of up to 120 minutes (EI 120).

The product is
certificated on the
basis of:

- i) Inspection and surveillance of factory production control by UL
- ii) Fire resistance test data in accordance with EN 1366-3:2021 & EN 1366-3:2021+A1:2024
- iii) Classification in accordance with EN 13501-2:2023
- iv) Durability and Serviceability as defined in EAD 350454-00-1104

The durability class of FirePro Flex Seal is Type X: Intended for use at conditions exposed to weathering.

According to EN 1366-3: 2021+A1: 2024, Clause H.4.1.8.6.2, the following end uses are envisaged* based upon the tested pipe end configuration:

Pipe material	Tested pipe end	Envisaged use scenario
Metal	C/U or C/C	Closed pipe systems (e.g. systems under pressure)
	U/U, U/C or C/U	Ventilated pipe systems (e.g. sewage pipes) and for closed pipe systems
Plastic	U/U or C/U	Ventilated pipe systems and for closed pipe systems
	U/U	Ventilated pipe systems, for rainwater systems and for closed pipe systems

* In the case where a national prescription is in conflict with the content of the table above, the national prescriptions prevail.



Appendix UL-EU CERTIFICATE UL-EU-01351-EN

3 Performance of the product and references to the methods used for its assessment

Product-Type: Coated Board		Intended Use: Penetration Seal	
Assessment Method		Essential Characteristics	Product Performance
BWR 2 Safety in case of fire			
EN 13501-1		Reaction to fire	No performance assessed
EN 13501-2:2023		Resistance to fire	See Annex C, pages 7 to 17
BWR 3 Hygiene, health and the environment			
Declaration of Manufacturer & EN 16516		Content, emission and/or release of dangerous substances	Use categories: IA1 Declaration of manufacturer For VOC and SVOC test results, see Annex A, page 4
EN 1026:2016		Air Permeability (Material Property)	No performance assessed
EN 1027:2016		Water Permeability (Material Property)	No performance assessed
BWR 4 Safety and accessibility in use			
EAD 350141-00-1104, Clause 2.2.6		Mechanical resistance and stability	No performance assessed
EAD 350141-00-1104, Clause 2.2.7		Resistance to impact/movement	No performance assessed
EAD 350141-00-1104, Clause 2.2.8		Adhesion	No performance assessed
EAD 350141-00-1104, Clause 2.2.9		Durability	Type X
BWR 5 Protection against noise			
EN 10140-2:2021		Airborne sound insulation	Rw(C; Ctr) 36 (-1;-3) (Minimum) See Annex B, pages 5 & 6
BWR 6 Energy economy and heat retention			
EN 12664, EN 12667, EN 12939, EN ISO 8990, EN ISO 6946, EN ISO 10456		Thermal properties	No performance assessed
EN ISO 12572, EN 12086, EN ISO 10456		Water vapour permeability	No performance assessed



Appendix UL-EU CERTIFICATE UL-EU-01351-EN

Annex A - Hygiene, health and the environment - Content, emission and/or release of dangerous substances

FirePro Flex Seal: Analytical VOC Results***		
Density, g/mL	VOC content (less water), mg/m ³	VOC limit mg/m ³
1.45	2.6·10 ⁶ *	1.4·10 ⁸ **

VOC Content Test Report Number: 392-2025-00181007_XG_EN

VOC Emission Test Report Number: 392-2025-00181002_A_EN_Rockwool Ltd_IAC GOLD

* 2.6·10⁶ mg/m³ of unidentified substances, in addition to VOC content.





** VOC limit for “Decopaint”, Paints and Varnishes scope, Directive 2004/42/CE.

***No SVOC compounds were determined as per VOC Emission test report 392-2025-00181002_A_EN_Rockwool Ltd_IAC GOLD.



Appendix UL-EU CERTIFICATE UL-EU-01351-EN

Annex B - Protection against noise – Airborne sound insulation


FirePro Flex Seal: Acoustic performance according to EN ISO 10140-2:2021		
Configuration	Rw(C; Ctr) Partition & Specimen, 10.95m ²	Test results
 <p>Base Wall British Gypsum A216012(A) (EN) 64 Rw (dB) / 58 Rw+Ctr (dB)</p>		61 (-2;-8)
 <p>ROCKWOOL FirePro FlexSeal 1100x1100mm opening</p>		36 (-1;-3)



Solutions

Form-ULID-006104 V10.0

Appendix UL-EU CERTIFICATE UL-EU-01351-EN



Solutions


Form-ULID-006104 V10.0

Appendix UL-EU CERTIFICATE UL-EU-01351-EN

Annex C – Safety in case of fire – Resistance to Fire classification

C.1 Double Skin Flexible walls $\geq 100\text{mm}$

C.1.1 Blank Seal – framed and lined openings

			
Service type	Aperture size	Service protection	Classification
Blank	1200 x 2000 mm	100 mm thick FirePro® Flex Seal Coated Strip, installed with 4mm compression on height & width, fitted centrally within the aperture. All edges and butt joints sealed with FirePro® AIS sealant. Additional layer of FirePro Flex Seal Coating applied after installation.	EI 120

Appendix UL-EU CERTIFICATE UL-EU-01351-EN

C.1.2 Cable Penetrations - unlagged

Service type		Service size (mm)	Service protection	Classification
Sheathed cables	S	≤21	100 mm thick FirePro® Flex Seal Coated Strip, installed with 10 mm compression on height & width, fitted centrally within the aperture. All edges and butt joints sealed with FirePro ® AIS sealant. Additional layer of FirePro Flex Seal Coating applied to both faces after installation.	E 120 / EI 60
	M	≤50		E 120 / EI 60
	L	≤80		E 120 / EI 60
Cable bundle		≤Ø100 cable bundle of ≤Ø21 cables		E 120 / EI 60
Unsheathed cables		≤24		E 120 / EI 30
Galvanized steel trays, stainless steel trays, non-perforated steel trays and cable ladders		Unrestricted		E 120 / EI 60



Appendix UL-EU CERTIFICATE UL-EU-01351-EN


C.1.3 Cable Penetrations - Lagged

<p>Diagram illustrating two types of cable penetration through a wall, showing the application of FirePro® Flex Seal Coating and FirePro® AIS sealant.</p> <p>Top Section (Single cable penetration):</p> <ul style="list-style-type: none">Flexible wallFramed and lined openingSingle cable penetration (See table)Services supportDuctWrap 300mm long Locally Interrupted (LI)FirePro® Flex Seal Coating applied to faceCable bundle penetration (See table)Services supportFirePro® AISFirePro® Flex Seal Coated StripAdditional application of FirePro® Flex Seal Coating applied to both faces after installation <p>Bottom Section (Cable bundle penetration):</p> <ul style="list-style-type: none">Flexible wallFramed and lined openingSingle cable penetration (See table)Services supportDuctWrap 300mm long Locally Interrupted (LI)FirePro® Flex Seal Coating applied to faceCable bundle penetration (See table)Services supportFirePro® AISFirePro® Flex Seal Coated StripAdditional application of FirePro® Flex Seal Coating applied to both faces after installation				
Service type		Service size (mm)	Service Protection	Classification
Sheathed cables	S	≤21	100 mm thick FirePro® Flex Seal Coated Strip, installed with 10 mm compression on height & width, fitted centrally within the aperture. All edges and butt joints sealed with FirePro® AIS sealant. Additional layer of FirePro Flex Seal Coating applied after installation.	EI 120
	M	≤50		E 120 / EI 60
	L	≤80		E 120 / EI 60
Cable bundle		≤Ø100 cable bundle of ≤Ø21 cables	40 mm ROCKWOOL® DuctWrap, cut to size and wrapped around the service item in a local interrupted configuration 300 mm to both faces and secured to service with steel wire.	EI 120
Unsheathed cables		≤24		EI 120
Perforated steel tray, or basket		Unrestricted		EI 120
Cable ladder		Unrestricted		EI 120



Appendix UL-EU CERTIFICATE UL-EU-01351-EN


C.1.4 Plastic Pipe Penetrations – FirePro PWRoll




Pipe material	Pipe size (mm)	Pipe Wrap layers (2mm)	Service Protection	Classification
PP/PE/PVC	≤40	1	100 mm thick FirePro® Flex Seal Coated Strip, installed with 10mm compression across the width, fitted centrally within the aperture. All edges and butt joints sealed with FirePro® AIS sealant. Additional layer of FirePro Flex Seal Coating applied after installation. FirePro® PWROLL wraps installed flush with each face of the seal, around the service.	E 120/EI 90 U/C
	41-79	2		
	80-120	3		
	121-160	4		



Appendix UL-EU CERTIFICATE UL-EU-01351-EN




Appendix UL-EU CERTIFICATE UL-EU-01351-EN



Appendix UL-EU CERTIFICATE UL-EU-01351-EN

C.2 Rigid walls $\geq 100\text{mm}$

C.2.1 Blank Seal

 <p>The diagram illustrates the installation of a fire-rated sealant system on a rigid wall. On the left, a top-down view shows a rectangular aperture of 1200 mm width and 2000 mm height. A 100 mm thick FirePro® Flex Seal Coated Strip is installed centrally within the aperture. The strip is surrounded by FirePro® AIS sealant. On the right, a cross-section view shows the rigid wall (100 mm thick) with the FirePro® Flex Seal Coated Strip installed. The strip is sealed with FirePro® AIS sealant. The diagram also shows the additional application of FirePro® Flex Seal Coating to both faces of the strip after installation.</p>			
Service type	Aperture size	Service protection	Classification
Blank	1200 x 2000 mm	100 mm thick FirePro® Flex Seal Coated Strip, installed with 4mm compression on height & width, fitted centrally within the aperture. All edges and butt joints sealed with FirePro® AIS sealant. Additional layer of FirePro® Flex Seal Coating applied after installation.	EI 120



Solutions

Form-ULID-006104 V10.0

Appendix UL-EU CERTIFICATE UL-EU-01351-EN

C.2.2 Cable Penetrations - unlagged

Service type		Service size (mm)	Service protection	Classification
Sheathed cables	S	≤21	100 mm FirePro® Flex Seal Coated Strip, installed with 10 mm compression on height & width, fitted centrally within the aperture. All edges and butt joints sealed with FirePro® AIS sealant. Additional layer of FirePro Flex Seal Coating applied after installation.	E 120 / EI 60
	M	≤50		E 120 / EI 60
	L	≤80		E 120 / EI 60
Cable bundle		≤Ø100 cable bundle of ≤Ø21 cables		E 120 / EI 60
Unsheathed cables		≤24		E 120 / EI 30
Galvanized steel trays, stainless steel trays, non-perforated steel trays and cable ladders		Unrestricted		E 120 / EI 60



Appendix UL-EU CERTIFICATE UL-EU-01351-EN


C.2.3 Cable Penetrations - Lagged

Service type		Service size (mm)	Service Protection	Classification
Sheathed cables	S	≤21	100 mm thick FirePro® Flex Seal Coated Strip, installed with 10 mm compression on height & width, fitted centrally within the aperture. All edges and butt joints sealed with FirePro® AIS sealant. Additional layer of FirePro Flex Seal Coating applied after installation. 40 mm ROCKWOOL® DuctWrap, cut to size and wrapped around the service item in a local interrupted configuration 300 mm to both faces and secured to service with steel wire.	EI 120
	M	≤50		E 120 / EI 60
	L	≤80		E 120 / EI 60
Cable bundle		≤Ø100 cable bundle of ≤Ø21 cables		EI 120
Unsheathed cables		≤24		EI 120
perforated tray, or basket		Unrestricted		EI 120
Cable ladder		Unrestricted		EI 120




Appendix UL-EU CERTIFICATE UL-EU-01351-EN


C.2.4 Plastic Pipe Penetrations – FirePro PWRoll



Pipe material	Pipe size (mm)	Pipe Wrap layers (2mm)	Service Protection	Classification
PP/PE/PVC	≤40	1	100 mm thick FirePro® Flex Seal Coated Strip, installed with 10mm compression across the width, fitted centrally within the aperture. All edges and butt joints sealed with FirePro® AIS sealant. Additional layer of FirePro Flex Seal Coating applied after installation. FirePro® PWROLL wraps installed flush with each face of the seal, around the service.	E 120 / EI 90 U/C
	41-79	2		
	80-120	3		
	121-160	4		



Appendix UL-EU CERTIFICATE UL-EU-01351-EN



Appendix UL-EU CERTIFICATE UL-EU-01351-EN

The UL-EU Marks, displayed below represent the enhanced and alternate version of the product marking. Either Mark can be used. These Marks shall appear on certified products only. Minimum size is not specified, as long as the Mark is legible. The following is suggested.



*Note: E12345 is an example of the UL file number.

The minimum height of the registered trademark symbol ® shall be 1 mm. When the overall diameter of the UL-EU Mark is less than 9.5 mm, the trademark symbol may be omitted if it is not legible to the naked eye.

The UL-EU Mark may appear on a label, nameplate, or may be cast, stamped or molded into the product. When appearing on a label or nameplate, the Manufacturer's name or trademark along with a model number and UL File number are also required on that same label or nameplate. If cast, stamped or molded, the Manufacturer's name or trademark and model number shall also appear elsewhere on the product.

All content shall be in accordance with the details provided on this UL-EU Certificate.

PROCUREMENT

The Production site may reproduce the Mark or obtain it from a UL authorized supplier. The list of UL authorized suppliers can be found on UL's online directory at www.ul.com.



Solutions

Form-ULID-006104 V10.0